

4.0 BUILDING 3440: BLANCHARD GRADER STATION

4.1 Description of Existing Water Supply System

Building 3440, the Blanchard Grader Station and Building 3441, the Blanchard Living Complex, are currently served by a water supply system that delivers water from a well of unknown depth. Midnight Sun Drilling Company (MSD) drilled the well, however, neither MSD nor YTG have been able to provide a log for this well. The well is located in an enclosure off the maintenance room of the grader station. The well location and other details about the surrounding area are provided in Figure 3440-A in Appendix A4. The coordinates of the wellhead, as measured by a handheld GPS device, were recorded as:

- UTM ZONE 8
- Northing: 6653029
- Easting: 396549

There is no treatment or disinfection system for the water supplying the maintenance garage. As such, the kitchen area in the lounge of the Grader station receives untreated water. The water system that supplies the living complex is equipped with a NSF 61 filtration system that is followed by a UV disinfection system and a reverse osmosis treatment system. The treatment system is located in the maintenance garage and post-treatment water is stored in a 5000 L water storage tank before being piped to the living complex. A schematic detailing the water supply system is provided as Figure 3440-B in Appendix A4.

4.2 Description of Existing Wastewater Systems

Septic effluent from both the maintenance garage and the living complex is piped to a communal discharge system north of both the maintenance garage and living complex. The septic discharge system is greater than 80 m cross-gradient from the well. A site plan showing the septic system is given by Figure 3440-A in Appendix A4.

4.3 Water Quality Results

4.3.1 Water Quality Results from Previous Sampling

Bacteriological

Nine samples were collected from the Blanchard Grader Station water system between September 2004 and June 2005 and were tested for total coliform and *E. coli* by Yukon

Environmental Health Services using the presence/absence test method. Results are tabulated in Table 3440-1 in Appendix A4. Coliform bacteria and *E. coli* were reported as absent in each of the nine samples for which results are provided.

Potability

Water samples were previously collected from the Blanchard Grader Station water system on September 21, 2004 and June 15, 2005. The samples were submitted to Northwest Labs in Surrey, BC and ALS Environmental in Vancouver, BC for potability analyses. The results of these analyses are summarized in Table 3440-2 in Appendix A4. EBA reviewed the analytical results to compare them with the Canadian Drinking Water Quality Guidelines (CDWQG) to observe general water quality, identify and recommend additional sampling and analytical, and to identify indicators of potential contamination. The following observations were made:

- The raw water quality results indicated that all health based and aesthetic objectives were met for the parameters analyzed;
- The untreated water quality results indicated that the groundwater from this well is a calcium bicarbonate type water; and,
- The hardness (as CaCO₃) of the untreated water was 198 mg/L during the first sampling event, and is considered very hard. During the second sampling event the hardness (as CaCO₃) was 102 mg/L, and is considered moderately hard.

4.3.2 Identification of Additional Analytical Testing Required

Additional analytical for the Blanchard Grader Station included during the water system assessments is detailed below:

- UV absorbance and UV transmissivity, as well as tannins and lignin, to determine potential for UV treatment as a disinfection option for this water system;
- Total organic carbon (TOC);
- Extractable Petroleum Hydrocarbon (EPH) to determine any potential impacts of hydrocarbon contamination; and,
- Measurements in the field for total dissolved solids, conductivity, pH, and temperature.

Additionally, as no water quality data was taken previously from the living quarters water system, a sample was obtained for potability analysis.

Additional Analytical Results

A water sample was obtained during the water system assessment on July 29, 2005, and was submitted to ALS Environmental in Vancouver, BC for analysis. These results are summarized in Table 3440-2 in Appendix A4 and the laboratory reports are included in Appendix B. Items to note are:

- The analyses done on the water from the living complex reported the pH to be 6.10, which is below the CDWQG aesthetic objective lower limit of 6.5. Field chemistry done at the time of sampling, however, reported the pH to be 7.86. This shows that the pH at the point of use is likely within the CDWQG aesthetic objective; and,
- Water quality analysis reported no other exceedences of CDWQG MACs or aesthetic objectives.

4.3.3 Indicators of Potential Contamination

Analytic results for EPH indicated EPH concentrations below laboratory detection limits.

Chloride, nitrate and nitrite concentrations can indicate impacts from surfacewater sources or septic waste. Chloride concentrations were reported to be low and are considered to be within the normal background ranges for groundwater in the area. Nitrate and nitrite concentrations for this sample are also low and within the normal background range for this area. These water quality results do not suggest that the aquifer from which the groundwater is obtained for the Blanchard Grader Station is under the influence of surfacewater sources or septic wastes.

4.4 Conceptual Hydrogeology

There is no well log available for review for this well or for any other wells in the area. The direction of groundwater flow in the vicinity of the site as inferred from topographical maps and aerial photographs is likely westerly towards the Blanchard River.

4.5 Potential Contaminant Sources

Potential contaminant sources from observations made during the water system assessment are compiled in field notes in Appendix A4. Photos of potential contaminant sources are also provided in Appendix A4.

Potential contaminant sources within 30 m of the wellhead are:

- An above ground fuel storage tank (AST) at 21 m;
- An above ground fuel storage tank (AST) at 24 m; and,
- A fueling area at 21 m.

In addition, a tar emulsion above ground storage tank is located 31 m away from the wellhead, and bulk fuel storage tank is located at 36 m. The bulk fuel tank is located within a secondary containment berm to contain spillage/ leaks. The closest portion of a septic system to the wellhead is a septic line located 30 m away. The closest septic field is approximately 80 m away from the wellhead.

4.5.1 Spills Records and Contaminated Sites Search Results

The Government of Yukon Environmental Programs Branch and Environment Canada Environmental Protection Branch did not identify any recorded spill events or contaminated sites issues for this site or neighbouring sites. During the site assessment, however, it was noted that there are monitoring wells located downgradient of the bulk fuel storage area. The purpose of these monitoring wells is unknown, however their existence indicates the completion of some sort of environmental investigation, likely related to the bulk fuel storage. As the bulk fuel storage area is inferred to be significantly downgradient of the water supply well, the risk of drinking water contamination from any existing contamination in the area is considered to be low.

4.6 Identified Water System Deficiencies and Associated Risk

4.6.1 High and Medium Risk Deficiencies

- There is no treatment or disinfection on the water system supplying the maintenance garage;
- There is a vehicle fueling area located approximately 21 m upgradient from the well;
- There is no well log available to review well construction and lithology; and,
- By definition of the Draft Yukon GUDI Assessment Guideline, the well is potentially under the direct influence of surface water because the completion depth is unknown, and the well construction does not meet the requirements of the CGWA Guidelines for Water Well Construction.

4.6.2 Low Risk Deficiencies

- The wellhead is only approximately 150 mm above grade, but is located in an appropriately constructed enclosure with a low risk of flooding, and is approximately 450 mm above the floor of the enclosure.

4.7 Mitigative Options for Deficiencies

Mitigative options were developed to address the deficiencies identified in the previous section. Deficiencies are categorized by recommended level of priority (with Priority 1 being most critical).

4.7.1 Priority 1

- Re-plumb the treated water to provide potable water to dedicated taps in the bathroom and kitchen area of the maintenance garage.
- A further attempt should be made to obtain the well record to assess aquifer and well vulnerability. If a well record cannot be obtained, the overall well depth should be determined at the very least.

4.7.2 Priority 2

- As indicated previously, two large Enviro Tanks and a fueling area are located approximately 20 m in a direction that is inferred to be upgradient of the well. Although the tanks are double walled, and there is a secondary containment tray beneath the fuel pumps, it is evident that vehicles are re-fueled in front of this fueling area. There is a risk of overfilling, and potential contamination of the subsurface and aquifer that provides water to the buildings at the site. It would be prudent to relocate the fueling area downgradient, or cross gradient and at least 60 m from well to protect the water quality.

4.7.3 Priority 3

- To limit potential contaminants entering the wellhead, or traveling down the outside of the casing, it is recommended that the casing be extended to 500 mm above grade, and the concrete floor elevation be raised to grade.

4.8 Cost Estimates for Mitigative Options

Engineering costs for mitigative options are estimated to be 20% of construction costs, and would include inspection and completion reporting. The costs for materials and labour (not including engineering) are provided in the sections below. An additional contingency allowance of 20% is suggested for budgetary purposes.

4.8.1 Priority 1


- It is estimated that materials and labour to upgrade the plumbing such that the kitchen area and washroom sink within the maintenance garage can be supplied with treated (filtered, UV and RO) water, would cost in the order of \$250 for materials and labour.

4.8.2 Priority 2


- To relocate the Enviro-tanks to an area that is at least 60 m west, or 30 m south of the well location would cost approximately **\$600**.

4.8.3 Priority 3

- To extend the wellhead to at least 500 mm above grade, and to raise the elevation of the concrete floor to grade level, would cost in the order of **\$400** for materials and labour.



NOTES:
 1. UTM COORDINATES OBTAINED WITH A HAND HELD GPS USING NAD83 SYSTEM AND ARE CONSIDERED TO BE ACCURATE TO 10.0 m, APPROXIMATELY.

 30 m RADIUS FROM WATER WELL FOR CONSIDERATION OF PROXIMITY TO POTENTIAL CONTAMINANT SOURCES.

No.	DESCRIPTION	DATE	APPROVED
0	ISSUED FOR CLIENT REVIEW	DD/MM/YY	XXX
	REVISION		

EBA Engineering Consultants Ltd.

DESIGNED BY: R. MARTIN
 DRAWN BY: J. BUYCK
 DATE: AUG. 2005
 SCALE: AS SHOWN
 PROJECT No.: 1260002.003
 ACAD FILENAME: 003-WESTERN REGION

CLIENT:
Yukon
 Highways and Public Works
 Property Management Branch


SMALL PUBLIC WATER SYSTEMS ASSESSMENT
 WESTERN REGION

GOVERNMENT OF YUKON
 HIGHWAYS & PUBLIC WORKS



BLANCHARD CAMP GRADER
 STATION BUILDING # 3440
 SITE LOCATION DIAGRAM
 WELL ID: 3440

REVISION ISSUE
 0

FIGURE No.
 FIGURE 3440-A



SCHEMATIC PRODUCED BY BERT ALBISSER OF AQUA TECH SUPPLIES AND SERVICES LTD.

 EBA Engineering Consultants Ltd.		PROJECT SMALL PUBLIC WATER SYSTEMS ASSESSMENT WESTERN REGION	
CLIENT 		TITLE WATER SYSTEM DISTRIBUTION/TREATMENT SCHEMATIC SYSTEM ID.: 3440 BLANCHARD CAMP GRADER STATION	
DATE	SEPT. 2005	DWN.	JSB
CHKD.	RMM	FILE NO.	1260002.003
		DWG.:	FIGURE 3440-B

Western Region - BLANCHARD CAMP
 Building # 3440

DISTRIBUTION & TREATMENT SYSTEM DATA

Item	Description	Manufacturer	Model	Part No.	Serial No.	Size
1	SOFTENER	HYDROTECH	ELITE6730MI			30K.
2	R.O. SYSTEM	US FILTER	US1800		Rated @	2200 GPD
3	HOLDING TANK	ZEEBEST	1250 AG.			1250 GALLONS
4	FLOAT CONTROL	SJE PUMPMASTER	PUMPUP			240 230V
5	JET PUMP	MONARCH	JKS-3			3/4 HP.
6	PREFILTER	AQUA TECH	DUPLEX BIG BLUE	R30BB J01DP97	} CARTRIDGES	
7	UV STERILIZER	R-CAN	UVAQ012		2023381	
8						
9						
10						

TABLE 3440- 1: SUMMARY OF BACTERIOLOGICAL RESULTS

		Number of Sampling Events	Time Period over which Sampling was Done	Any Positive Total Coliform Results? (yes or no)	Fraction of Positive Total Coliform Results vs. Total Sampling Events	Any positive E.Coli results? (yes or no)	Most Recent Sampling Event Available for EBA Review	Is Most Recent Result Positive?
Building #	Building Name							
3440	Blanchard Grader Station	9	Sept-04 to Jun-05	no	0/9	no	16-Jun-05	no



Table 3440-2: Water Quality Results

SOURCE: Building 3440 - Blanchard Grader Station						GCDWQ Criteria				
Location/ Resident	Haines Road									
Address										
Treatment	None			Filtration, softener, RO						
Disinfection	None			UV disinfection						
Source of Water	On-site well									
Purpose of Sampling	Base Line	Base Line	Additional Analytical	Additional Analytical						
Sample Location	Grader Station	Grader Station	Grader Station	Living Complex						
Date Sampled	21-Sep-04	15-Jun-05	29-Jul-05	29-Jul-05	Lower	Upper Limit				
Physical Tests (ALS)					AO	MAC	AO			
Colour (CU)	<5.0	<5.0	-	<5.0			15			
Conductivity (uS/cm)	218	218	-	2.8						
Total Dissolved Solids	212	124	-	<10			500			
Hardness CaCO3	198	102	-	<0.66	AO >200 = poor, > 500 unacceptable ^A					
pH	8.09	8.17	-	6.10	6.5		8.5			
Turbidity (NTU)	0.3	0.4	-	0.64		1	5			
UV Absorbance			<0.0050	-						
% UV Transmittance			99.3	-						
Dissolved Anions (ALS)										
Alkalinity-Total CaCO3	163	89.7	-	1.9						
Chloride Cl	5.7	8.59	-	<0.50			250			
Fluoride F	<0.05	0.028	-	<0.020		1.5				
Silicate SiO4			-	-						
Sulphate SO4	30.4	10.4	-	<0.50			500			
Nitrate Nitrogen N	0.5	<0.10	-	<0.10		10				
Nitrite Nitrogen N	<0.05	<0.10	-	<0.10		3.2				
Ammonia Nitrogen N			-	-						
Total Phosphate PO4			-	-						
Total Metals (ALS)										
Aluminum T-Al	<0.005	<0.010	-	<0.010						
Antimony T-Sb	<0.0002	<0.00050	-	<0.00050		0.006				
Arsenic T-As	0.0005	0.0006	-	<0.00010		0.025				
Barium T-Ba	0.039	0.066	-	<0.020		1				
Boron T-B	0.023	<0.10	-	<0.10		5				
Cadmium T-Cd	<0.00001	<0.00020	-	<0.00020		0.005				
Calcium T-Ca		30.3	-	<0.10						
Chromium T-Cr	0.001	<0.0020	-	<0.0020		0.05				
Copper T-Cu	0.032	0.0484	-	0.107		1				
Iron T-Fe	0.01	<0.030	-	<0.030			0.3			
Lead T-Pb	0.0004	0.0011	-	0.0011		0.01				
Magnesium T-Mg		6.38	-	<0.10						
Manganese T-Mn	<0.005	<0.0020	-	<0.0020			0.05			
Mercury T-Hg		<0.00020	-	<0.00020		0.001				
Potassium T-K		2.66	-	0.45						
Selenium T-Se		0.0017	-	<0.0010		0.01				
Sodium T-Na		<2.0	-	<2.0			200			
Uranium T-U	<0.0005	0.00075	-	<0.00010		0.02				
Vanadium T-V			-	-						
Zinc T-Zn	0.175	0.057	-	<0.050			5			
Organic Parameters										
Tannin and Lignin			<0.10	-						
Total Organic Carbon C			0.81	-						
Extractable Hydrocarbons										
EPH10-19			<0.30	-						
EPH19-32			<1.0	-						
Field Chemistry (EBA)										
pH			8.59	7.86	6.5		8.5			
TDS (ppm)			83	<1			500			
EC (uS/cm)			175	<1						
Temperature (°C)			7.3	16.4						
Free Available Chlorine										

Notes:

A. Guidelines indicated for hardness are not CDWQG, rather they are general aesthetic guidelines

- exceedences are indicated in yellow highlighting.

italics and underline indicates exceedence of proposed MAC (ie. arsenic)

Bold with Yellow highlighting indicates exceedence of CDWQG Aesthetic Objective (AO)

Underline with Yellow highlighting indicates exceedence of CDWQG MAC

Results are expressed as milligrams per litre except for pH and Colour (CU)

Conductivity (umhos/cm), Temperature (°C) and Turbidity (NTU)

< = Less than the detection limit indicated.

AO = Aesthetic Objective

MAC = Maximum Acceptable Concentration (Health Based)



EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

SMALL PUBLIC WATER SYSTEM ASSESSMENT

PART A: EBA Site Inspection

Inspector: Ryan Markin, Luke Lebel

Date July 29, 2009

WELL ID #	Owner	Location Description
3440	YTG	Blanchard Grader Station

1. Well Location and Potential Contaminant Sources

a. General location of well: (Community, Subdivision, etc.)

Haines Road

b. Specific location: (Road or street, Building number, name of owner and/, legal description,

c. GPS location: N 6653029 E 396549 elev 837m ± 9m

d. Is there electric power? Yes No

e. Is there outside water access? Yes No

On living complex

f. Does the well system have:

15 or more service connections to a piped distribution system? If so how many _____

Living complex and Maintenance garage

5 or more delivery sites on a trucked distribution system? If so how many _____

g. Nearest building, specify Located in enclosure off from
maintenance garage

h. Distance from well to building _____

i. If there is an effluent disposal field, is its location known? Yes No

j. Distance from well to nearest point of known field: >60 m

k. Well location relative to field: upslope downslope lateral

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

l. Is there any part of a sewage disposal system(s) or other potential sources of pollution that may pose a health and safety risk within 30 m? Yes No

Septic service lines

m. Is the well located within 300 m from a sewage lagoon or pit? Yes No unlikely

n. Is the well located within 120 m from a solid waste site or dump, cemetery? Yes No unlikely

o. Is the infrastructure protecting the wellhead, pumphouse, storage tank and/or water treatment plant designed and secured to prevent:

Unauthorized access by humans? Yes No
located in locked building off of pump room

Entrance by animals? Yes No
But access is possible

p. Is well site subject to flooding? Yes No

q. Is the well site well drained? Yes No

r. Is there a buried fuel tank on the property? Yes No unlikely

If yes, is it in use abandoned

Is the location known? Yes No

Distance from the well to known buried tank _____

s. Are there any other known contaminant sources on the property?

Yes No Describe _____

If yes, specify the source: dump sewage lagoon cemetery other
Rock Pit

Potential Source 1: AST 1; Distance from well to Potential Source 1: ~21m

Potential Source 2: AST 2; Distance from well to Potential Source 2: ~24m

Potential Source 3: Fueling area; Distance from well to Potential Source 3: ~21m

Potential Source 4: Tar or emulsion tank; Distance from well to Potential Source 4: ~31m
Bulk tank @ 36m (bermed w/ berm @ ~29m)

t. Are there other wells on this property? Yes No

How many? _____ in use abandoned require proper sealing

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

2. Well and Wellhead information:

- a. When was well installed? Year unknown Month _____
- b. Type: drilled dug sand point other _____
- c. Is there a drillers log for the well: Yes No
- d. Is there a surface seal to 6 m Yes No unknown unlikely
- e. Surface casing: Yes Diameter _____ No
- f. Well casing: Diameter 20cm Material: steel plastic concrete
- g. Depth of well: unknown measured (if possible) reported from log
- h. Static water level below ground: unknown
 measured (if possible) reported from log flowing
- i. (If granular) Is the well completed: open end casing with a well screen
 with slotted pipe unknown other _____
- j. (If bedrock) Does the well have a liner? yes No steel plastic
- k. If there is a well screen: length _____ slot size(s) _____
Location of screen: from _____ to _____ from log reported
- l. Is there a sump below the screen? Yes No unknown, unlikely
- m. Is the well head: in pumphouse in pit pitless adaptor in a building
 in a wooden enclosure other, describe _____
- n. If the well head is located in a wooden enclosure,

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

- i. Is the well head below grade? describe in detail ~0.15m above grade, ~0.45m above floor
- ii. Are there signs of ponding on the enclosure(e.g. water stains, etc.)? Yes No
- iii. Is the wellhead enclosed by fiberglass insulations? Yes No in walls of enclosure
- iv. Any evidence of rodents? Specify No, access possible
- v. Does the well casing have a proper seal cap? Yes No

If no, describe condition _____

3. Water Supplying This Well:

- a. By definition is the water from a surface water source or under the direct influence of surface water?
 Yes No farther investigation required.

If yes is there treatment or disinfection Yes No

Explain (filtration, disinfection etc...) UV, filtration, RO

4. Aquifer Supplying This Well:

- a. The aquifer is: bedrock granular sediment unknown
likely

- b. Does water level and/or well capacity show seasonal fluctuation? Yes No
unlikely

5. Pump Installation:

- a. Is the well equipped with a pump? yes No

- b. Type of pump: hand electric submersible jet

shallow well centrifugal other, _____

- c. Description: Manufacturer _____ Model _____
horsepower _____ capacity _____ voltage _____

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

d. Date installed: _____ By: _____

e. For submersible pump, depth of setting below surface _____

f. Drop pipe for submersible pump: steel plastic *unknown*

g. Pump delivers water to: pressure tank elevated tank other
(post RO water)

h. Are there automatic pump controls: Yes No

i. Is there provision for taking water samples before water reaches storage? Yes No

j. Is there a water meter on the system? Yes No

k. Is the pump and piping protected from freezing? Yes No

If yes, describe: Heated enclosure, Insulation, Likely Heat Trace

l. Comments on pump installation: _____

6. Conclusions

a. Comments on overall installation:

b. Recommendations: _____

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

PART B: EBA Site Inspection

Inspector: BERT ALBISSER

Date July 29/05

WELL ID #	Owner	Location Description
<u>3440</u>	<u>YTG.</u>	<u>BLANCHARD GRADLE STATION</u>

6. **Water Treatment** FOR RESIDENCE (SHOW WATER NOT TREATED).
- a. Is well water treated? Yes No; Type of treatment: SOFTENER & R.O SYSTEM
UV STERILIZER.
- chlorination iron and or manganese removal other _____
- b. Is water entering plumbing or piped distribution system treated with chlorine or another treatment that is as effective as chlorine used to achieve disinfection throughout the system?
- Yes No If so how _____
- c. If treated with chlorine, is the free residual chlorine concentration less than 0.2 mg/L
- Yes No _____ reading.
- Tested at _____ (location)
- d. Is testing for chlorine residual concentration done at the tap (eg. Kitchen faucet) or from representative points in a piped distribution system, including a point from tap at the end line
- Yes No If yes how often? _____
- e. If the drinking water is being transported by water delivery truck does it have a minimum chlorine free residual of 0.4 mg/L at the time of fill. Yes No

7. **Water Quality (observations):**

- a. Does the water stain plumbing? yes No slight severe
- Type of stain: brown red black
- b. Does the water contain sediment? Yes No occasional constant
- c. Is there an unpleasant odour? Yes No H₂S Other _____

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

- d. Is there an unpleasant taste? Yes No brackish Other _____
- e. Is there a history of bad bacterial analyses? Yes No
- f. Is there a chemical analysis? Yes No adequate incomplete
- g. Is there analysis of trihalomethanes (THMs) where the water source is a surface water supply or a well under the direct influence of surface water? Yes No
- h. Is the drinking water tested daily with an accurate reading chlorine test kit capable of reading in the range 0 to 3.5 mg/L of free chlorine residual in increments of 0.1mg/L? Yes No unknown
- i. If yes is the test performed in accordance with manufactures directions? Yes No unknown
- j. Is a record of the date, time, name of person performing the test and results of the drinking water sample kept? Yes No

TANK AND PIPING DETAILS

Tank Room

Is there a water tank? Yes No Details: 1200 GALLON FIBRE GLASS

Where is it located?

Comments: Shop Floor.

Is the room in which the water tank is located heated to maintain an optimum temperature of 4°C for stored water?

YES NO

Comments: _____

Are there windows in the add-on that may allow direct sunlight onto the water holding tank? YES

NO

Comments: _____

Are there other heat sources near the tank? YES NO

Comments: _____

Is there waterproof flooring with a sealed base to contain spills? YES NO

Comments: _____

Overall Tank

What are the tank size and dimensions?

1250 IMP GALLONS

What material is the tank constructed of? FIBRE GLASS

Is tank and associated piping constructed of safe materials (i.e. CSA approved and material that does not affect the taste of the water)? YES NO

Comments: _____

Tank Inlet, Outlet and Lid

Is there adequate access on the tank for cleaning (i.e. min 15" access lid)? YES NO

Does the lid have a tight seal and is it watertight when closed? YES NO

Does the tank have an overflow or high level whistle? YES NO

Is the water tank drain accessible? YES NO

WATER TANK AND WATER QUALITY CONDITION

Are there signs of staining or biofouling? YES NO

Comments: _____

Is there any sediment or scum in bottom of tank? YES NO

Comments: _____

Is there any odour associated with the water or tank? YES NO

Have there been any bacteriological analyses conducted previously? YES NO ?

Does the tank appear that it has been cleaned recently? YES NO

Are the tanks easily assessed for the purpose of cleaning and disinfection? YES NO

8. Conclusions

a. Comments on overall installation:

THIS IS A REASONABLE INSTALLATION. IT PROVIDES
TO QUALITY WATER TO THE RESIDENCE

b. Recommendations:

INITIATE A PROPER MAINTENANCE SCHEDULE
BI-ANNUAL FOR WELL SHOCK CHLORINATION
TANK CLEANING AND UV CLEANING.
CHANGE UV BULB YEARLY.
SET UP MAINTENANCE CHECK LIST
& TRAINING FOR PEOPLE RESPONSIBLE FOR
THE SYSTEM.
LASTLY CHECK WATER QUALITY REGULARLY.



Photo 0139: 3440 Blanchard Grader Station maintenance garage



Photo 0134: 3440 Blanchard Grader Station living complex



Photo 0138: 3440 Wellhead enclosure



Photo 0135: 3440 Bulk fuel storage tank with geomembrane and berm



Photo 0137: 3440 Above ground fuel storage tank



Photo 0136: 3440 Emulsion or tar tank



Photo 0141: 3440 Blanchard River



Photo 0132: 3440 Water storage tank (right), duplex filter (centre), UV disinfection system (top centre), reverse osmosis treatment system (bottom centre), water softener (left)