

WELL AND PUMP DATA

Location of Well Mile 7 Ashimuk Rd


County	Township Number	Range Number	Section No.	Fraction
	N or S	E or W		1/4 1/4 1/4

Property owner's name and address 101130015

Haines Junction, Y.T.

Street Address and City or Distance and Direction from Road Intersections

Show exact location of well in section grid with an 'x' Sketch map of well location

	Addition Name
	Block Number
	Lot Number

Well
House
↓ creek 200 yds

Well depth 38' Datum point from which all measurements are taken

Method of Drilling

Cable tool Hollow rod Driven Dug

Direct rotary Air rotary Bucket auger

Reverse rotary Jetted Flight auger

Use

Domestic Public supply Industrial

Irrigation Municipal Commercial

Test Well Heating or cooling Monitoring

Casing Type

Steel Threaded Height above/below surface _____

Galv Welded Drive shoe? Yes No

PVC Solvent welded

SS

_____ in to _____ ft Wgt _____ lb/ft Sch. No. _____ in to _____ ft

_____ in to _____ ft Wgt _____ lb/ft Sch. No. _____ in to _____ ft

_____ in to _____ ft Wgt _____ lb/ft Sch. No. _____ in to _____ ft

Remarks, Elevation, Source of Data, etc.

Borehole data

Formation Log	Color	Hardness	From	To
sandy gravel	med gray		0	4
gravel, some coarse "			4	20
clay with rock	med to light gray		20	30
gravel			30	38
Bedrock			38	-

Intake Portion of Well

Screen type _____ or open hole from _____ ft to _____ ft

Manufacturer _____

Material _____ Dia. _____

Fittings _____ Length _____

Set between _____ ft and _____ ft Slot _____

_____ ft and _____ ft Slot _____

_____ ft and _____ ft Slot _____

Filter Pack

Source _____ Gradation _____

Method of installation _____ Composition _____

Volume used _____ Depth to top of f.p. _____

Grout

Used? Yes No Volume used _____

Neat Cement Bentonite

Method of installation _____

Depth: from _____ ft to _____ ft

from _____ ft to _____ ft

Development

Method air Duration 1 hr

Dates Aug 12/93 Sand content after _____ hrs

Chemicals used _____

Static Water Level

22' ft below above grade

Date measured Aug 12/93

Pumping Water Level

After _____ ft below above grade Date _____

After _____ hrs pumping at _____ gpm

Specific Capacity 8-10 gpm/ft of drawdown at _____ hours

Date Aug 12/93

Pump

Date installed _____ Type _____

Manufacturer _____ Model No. _____

H.P. _____ Volts _____ Capacity _____

Depth of pump intake setting _____ No. of stages _____

Oil Water lubrication Power source _____

Material of drop pipe _____ bowls _____

shafting _____ impellers _____ Bowl dia. _____

Column pipe dia. _____ Length _____ Modifications _____

Well Head Completion

Pitless adaptor Basement offset Distance above grade _____

Nearest Sources of Possible Contamination

100 ft Direction W Type septic

Well disinfected upon completion? Yes No

Geophysical Logs Run

Contractor Name and Address

WHITEWATER RESOURCES

Name of Driller _____

State License Number _____

Water Quality

Sample taken? Yes No

Where analyzed _____

Date well completed Aug 12/93