NTS MAP | WELL No. | ELEV | Location Accuracy | YR 91 MO 02 DY 05

UTM Z | E | N | Date 19__ | Well Type

Owners Name & Address: WHITEKIVER BAND

Legal Description & Address: BEAVER CREEK YUKON

Descriptive Location: TWO DWELLINGS PURCHASED FROM NORTHWESTEL

1. TYPE OF WORK: 1 ☑ New Well 2 ☐ Reconditioned 3 ☐ Deepened 4 ☐ Abandoned

2. WORK METHOD: 1 ☑ Cable tool 2 ☐ Bored 3 ☐ Jetted 4 ☐ Rotary a ☐ mud b ☐ air c ☐ reverse ☐ Other

3. WATER WELL USE: 1 ☑ Domestic 2 ☐ Municipal 3 ☐ Irrigation 4 ☐ Comm. & Ind. ☐ Other

4. DRILLING ADDITIVES: NONE USED

5. MEASUREMENTS from 1 ☐ ground level 2 ☑ top of casing

casing height above ground level _____ ft.

FROM ft	TO ft	6. WELL LOG DESCRIPTION	SWL ft
GL	3 9½'	course gravel & sand	
3 9½'	28'	" " "	
28	30'	small clumps of clay (No water)	
30'	31'	~~fine sand & pea gravel~~	
31'	48	Course sand & gravel	
44	45'	fine sand & pea gravel	
45'	51'	pea gravel	
51'	60'	sand & course gravel	
		SAND, course gravel at 60' Level	
6		course gravel & water	
		From 60' to 65' Ft.	
		DRILLED to 67-0'	
		Back in sand	
		dropped #15	
		Sandscreen at 65'-2"	
		and pulled casing	
		to Expose.	
		Baled for 4 HRS	
		while water cleaned	
		up. STATIC WATER	
		maintained @ 47'	
		Water Tested & Passed	
		By Health CANADA	
		Jan 23/97	

9. CASING: Materials 1 ☑ Steel 2 ☐ Galvanized 3 ☐ Wood 4 ☐ Plastic 5 ☑ Concrete ☐ Other

							units
Hole Diameter						6"	ins
Diameter	6.250 Starter pipe					3-9½"	ins
from	6" x .188 wall casing						ft
to							ft
Thickness	.625"					188	ins
Weight						1316	lb/ft

Pitless unit _____ ft 1 ☐ above 2 ☑ below ground level

1 ☐ Welded 2 ☐ Cemented 3 ☐ Threaded | 1 ☑ New 2 ☐ Used

Perforations: _____

Shoe(s): _____

Open hole, from _____ to _____ ft Diameter _____ ins

Grout: _____

10. SCREEN: 1 ☐ Nominal (Telescope) 2 ☐ Pipe Size

Type 1 ☑ Continuous Slot 2 ☐ Perforated 3 ☐ Louvre ☐ Other

Material 1 ☑ Stainless Steel 2 ☐ Plastic ☐ Other

Set from _____ to _____ ft below ground level

RISER, SCREEN & BLANKS							units
Length	4 Ft.						ft
Diam. I D	5"						ins
Slot Size	#15						ins
from	59'	10"					ft
to	65'	2"					ft

Fittings, top 4 Ft. RISER bottom Tail pipe

Gravel Pack _____

11. DEVELOPED BY: 1 ☐ Surging 2 ☐ Jetting 3 ☐ Air 4 ☑ Bailing 5 ☑ Pumping ☐ Other

12. TEST 1 ☐ Pump 2 ☐ Bail 3 ☐ Air Date YR 96 MO 09 DY 23

Rate _____ USgpm Temp _____ °C SWL before test _____ ft

Water Level _____ ft after test of _____ hrs

☐ DRAWDOWN in ft				☐ RECOVERY in ft			
mins	WL	mins	WL	mins	WL	mins	WL

13. RECOMMENDED PUMP TYPE: 3NFL52-8 | RECOMMENDED PUMP SETTING ft | RECOMMENDED PUMPING RATE: 8 g.p.m. USgpm

14. WATER TYPE: 1 ☐ fresh 2 ☐ salty 3 ☑ clear 4 ☐ cloudy

colour _____ smell _____ ; gas 1 ☐ yes 2 ☑ no

15. WATER ANALYSIS: 1 Hardness _____ mg/L 2 Iron _____ mg/L 3 Chloride _____ mg/L 4 pH _____ Field Date _____ Lab Date _____

7. CONSULTANT _____

Address _____

8. WELL LOCATION SKETCH

SITE I D No _____

PRESSURE TANK IN unit #1,



16. FINAL WELL COMPLETION DATA

Well Depth 65'-2" ft Well Yield _____ US gpm

Static Water Level 46 ft Artesian Flow _____ US gpm Pressure Head _____ ft

Back filled _____

Well Head Completion _____

17. DRILLER PLEASE PRINT [redacted] NAME

Signat [redacted]

18. CONTRACTOR, [redacted]

Address

Member, BCWWDA ☑ yes ☐ no ; _____

The Province of British Columbia accepts no responsibility for the contents or accuracy of this record.

Island Business Forms Ltd. 11139