


Property owner's name and address

# Water Well Log

Teslin Health Centre



Well site address

Teslin, V.T.

Sketch map of well location in the box above

Formation log	color	hardness	from	to	Well depth
Rocks + silt			0	6	108'
sandy silt			6	28	ground
boulder			28	30	Use Domestic
silty gravel			30	42	Industrial
bouldery gravel			42	55	Municipal
WET silt			55	97	Monitoring
fine gravel			97	108	Other <input checked="" type="checkbox"/>
					Method of drilling
					Cable tool <input type="checkbox"/> Air rotary <input checked="" type="checkbox"/>
					Other
					Casing type steel <input checked="" type="checkbox"/>
					welded <input checked="" type="checkbox"/> Drill shoe <input checked="" type="checkbox"/>
					shoe ID 4 1/2"
					Bole diameter
					5" to 108'
					Screen None
					Development method (washing)
					Air 3 hrs
					Static water level 34'
					Specific capacity 50 ± gpm
					Pump
					Other information

Whitewater Resources

Driller [Redacted]

Box 53412

Whitehouse, VT. V1A 5V5

1-(867) 667-6195

Date completed

Oct 11/99