NTS MAP | WELL No. | ELEV | Location Accuracy

UTM Z | E | N | UTM | Date 19 YR MO DY | Well Type

Owners Name & Address [redacted]

Legal Description & Address #1 Grayling Place

Descriptive Location Cowley Creek Whitehorse

1. TYPE OF WORK: 1 ☑ New Well 2 ☐ Reconditioned 3 ☐ Deepened 4 ☐ Abandoned

2. WORK METHOD: 1 ☑ Cable tool 2 ☐ Bored 3 ☐ Jetted 4 ☐ Rotary a ☐ mud b ☐ air c ☐ reverse ☐ Other

3. WATER WELL USE: 1 ☑ Domestic 2 ☐ Municipal 3 ☐ Irrigation 4 ☐ Comm. & Ind. ☐ Other

4. DRILLING ADDITIVES

5. MEASUREMENTS from 1 ☐ ground level 2 ☑ top of casing
casing height above ground level ft.

FROM ft	TO ft	6. WELL LOG DESCRIPTION	SWL ft
0	11	Sand + Grave	
11	27	Decomposed Rock	
27	63	Sand	
63	74	Clay + Gravel	
74	192	Open Hole - Bed Rock	

7. CONSULTANT

Address

8. WELL LOCATION SKETCH



9. CASING: Materials 1 ☐ Steel 2 ☐ Galvanized 3 ☐ Wood 4 ☐ Plastic 5 ☐ Concrete ☐ Other

							units
Hole Diameter							ins
Diameter	6"						ins
from							ft
to							ft
Thickness	188						ins
Weight	1316	Perfoot					lb/ft

Pitless unit ft 1 ☐ above 2 ☐ below ground level
1 ☐ Welded 2 ☐ Cemented 3 ☐ Threaded | 1 ☐ New 2 ☐ Used
Perforations:

Shoe(s): Drive Shoe
Open hole, from 74'6" to 192'0" ft Diameter 5¾ ins
Grout:

10. SCREEN: 1 ☐ Nominal (Telescope) 2 ☐ Pipe Size
Type 1 ☐ Continuous Slot 2 ☐ Perforated 3 ☐ Louvre ☐ Other
Material 1 ☐ Stainless Steel 2 ☐ Plastic ☐ Other
Set from to ft below ground level

RISER, SCREEN & BLANKS							units
Length							ft
Diam. I.D	None						ins
Slot Size							ins
from							ft
to							ft

Fittings, top Galvanized bottom
Gravel Pack None

11. DEVELOPED BY: 1 ☐ Surging 2 ☐ Jetting 3 ☐ Air 4 ☑ Bailing 5 ☑ Pumping ☐ Other

12. TEST 1 ☑ Pump 2 ☐ Bail 3 ☐ Air Date YR 03 MO 06 DY 30
Rate 1-2 USgpm Temp 2 °C SWL before test ft
Water Level ft after test of hrs

☐ DRAWDOWN in ft				☐ RECOVERY in ft			
mins	WL	mins	WL	mins	WL	mins	WL
0	128	17	0				
Recovery 1-2 Gallons Per Minute							

13.

RECOMMENDED PUMP TYPE	RECOMMENDED PUMP SETTING ft	RECOMMENDED PUMPING RATE USgpm

14. WATER TYPE: 1 ☑ fresh 2 ☐ salty 3 ☑ clear 4 ☐ cloudy
colour smell ; gas 1 ☐ yes 2 ☑ no

15. WATER ANALYSIS: 1 Hardness mg/L
2 Iron mg/L 3 Chloride mg/L
4 pH Field Date
SITE I D No Lab Date YR MO DY

16. FINAL WELL COMPLETION DATA
Well Depth 192 ft Well Yield 1-2 US gpm
Static Water Level 130 ft Artesian Flow US gpm Pressure Head ft
Back filled
Well Head Completion

17. DRILLER PLEASE PRINT [redacted]
Signatur

18. CONTRACTOR, [redacted]
Address

Member, BCWWDA ☐ yes ☑ no ;

The Province of British Columbia accepts no responsibility for the contents or accuracy of this record.

Island Business Forms Ltd. 11139

204100494