

Well Owner: [redacted]  
Address: #6 Cranberry Place

Phone: [redacted] Fax: \_\_\_\_\_

DATE: May 22/04

General Information

Well Location:  At owners address  Other

Water Quality:  Good  Poor, why \_\_\_\_\_

Water Analysis:  chemical  Biological  none

Comments: \_\_\_\_\_

Taste: good

Water use:  domestic  Stock  Garden

Irrigation  Heat pump  Industry

Community supply; number of connections \_\_\_\_\_

Other \_\_\_\_\_

Aquifer:  Rock  Sand and gravel

Well Capacity: Static Level. 53'

Capacity:  dry hole  Inadequate

Satisfactory for proposed use

Capacity test:  Bail test  Air lift  Pump test

Length of test \_\_\_\_\_ minutes Rate: \_\_\_\_\_

Water level at start: 53'

Drawdown at end: 96'

Estimated well capacity: 3 gal/min

Was a water sample taken at end of test?  Yes  No

Final well completion

Cover on casing  Welded plate  Pitless adaptor

Aluminium cover  Well seal

Casing:  above ground  In pit  In old dug well

Is casing sealed?  Yes  No

If Yes, describe: \_\_\_\_\_

Is site protected from obvious hazards, ie. poor drainage, grazing animals, buried fuel tanks, etc.  Yes  No

If no, what can be done? \_\_\_\_\_

If well location cannot be described from a road address, please sketch approximate location on reverse side of file copy of well record or attach separate sheet.

Driller: [redacted]  
Contractor: [redacted]  
Address: \_\_\_\_\_

Phone: 668-7208 Fax: \_\_\_\_\_

Well Log		Metres <input type="checkbox"/>	Feet <input checked="" type="checkbox"/>
From	To	Description	
0'	18	sandy gravel.	
18	132	clay	
132	136	loose, moist sand w/silts	
136	142	sandy gravel - water.	

\* If drilling is in rock, note depth of fractures which make water.

Well Construction

Surface Casing: Diameter \_\_\_\_\_  
Length \_\_\_\_\_ Stick up \_\_\_\_\_  
 removed  Left in place

Well Casing: Diameter 6"  
Length 145' 2 1/2' Stick up 18"  
Wall thickness: 250

Casing shoe  yes  no

Completion:  well screen  slotted pipe  
 open end  other

Well screen:  stainless  galvanized steel  
 plastic  
from 141 1/2" to 134 1/2" slot width 0.30  
from \_\_\_\_\_ to \_\_\_\_\_ slot width \_\_\_\_\_

Design based on:  sieve analysis  
 estimated slot size 2' 4 3/4"

Other screen data: screen has 2 1/4" riser.

Development method:  surge  bail  air

water jet  pump  other \_\_\_\_\_

Static water level below ground: 53'

flowing Rate: \_\_\_\_\_