

Well Owner: [Redacted]
Address: Lot #10 South Road
Phone: Fax:

Contractor:
Address:
Phone: Fax:

General Information

Well Location: [X] At owners address [] Other
Water Quality: [X] Good [] Poor, why
Water Analysis: [] chemical [] Biological [X] none
Comments:
Taste:
Water use: [X] domestic [] Stock [X] Garden
[] Irrigation [] Heat pump [] Industry
[] Community supply; number of connections
[] Other

Aquifer: [] Rock [X] Sand and gravel
Well Capacity
Capacity: [] dry hole [] Inadequate
[X] Satisfactory for proposed use
Capacity test: [X] Bail test [] Air lift [] Pump test
Length of test minutes Rate:
Water level at start:
Drawdown at end:
Estimated well capacity:

Was a water sample taken at end of test? [] Yes [X] No
Final well completion
Cover on casing [X] Welded plate [] Pitless adaptor
[] Aluminium cover [] Well seal
Casing: [X] above ground [] In pit [] In old dug well
Is casing sealed? [] Yes [X] No
If Yes, describe:
Is site protected from obvious hazards, ie. poor drainage,
grazing animals, buried fuel tanks, etc. [X] Yes [] No
If no, what can be done?

Well location cannot be described from a road address,
please sketch approximate location on reverse side of file
copy of well record or attach separate sheet.

Table with columns: Well Log, Metres, Feet, From, To, Description. Contains handwritten data for well depth and soil layers.

* If drilling is in rock, note depth of fractures which make water.

Well Construction
Surface Casing: Diameter Length Stick up
[] removed [] Left in place
Well Casing: Diameter 6"
Length 98'2" Stick up 1'6"
Wall thickness: .250"
Casing shoe [X] yes [] no
Completion: [X] well screen [] slotted pipe
[] open end [] other
Well screen: [X] stainless [] galvanized steel
[] plastic
from 100'8" to 96'8" slot width 18
from to slot width

Design based on: [X] sieve analysis
[] estimated slot size
Other screen data: bail bottom + K packer total length 4110"
Development method: [X] surge [] bail [] air
[] water jet [] pump [] other
Static water level below ground:
[] flowing Rate: