

Date: May 20/09

Well Owner: [Redacted]

Address: Lot 111 White Copper

Phone: _____ Fax: _____

Contractor: Pathway Water Resources

Address: _____

Phone: _____ Fax: _____

Driller: [Redacted]

General Information

Well Location: At owners address Other

Water Quality: Good Poor, why _____

Water Analysis: chemical Biological none

Comments: _____

Waste: _____

Water use: domestic Stock Garden

Irrigation Heat pump Industry

Community supply; number of connections _____

Other _____

Aquifer: Rock Sand and gravel

Well Capacity

Capacity: dry hole Inadequate

Satisfactory for proposed use

Capacity test: Bail test Air lift Pump test

Length of test 30 min minutes Rate: 1-5 gpm

Water level at start: _____

Drawdown at end: _____

Estimated well capacity: 1 to 2 gpm

Was a water sample taken at end of test? Yes No

Final well completion

Cover on casing Welded plate Pitless adaptor

Aluminium cover Well seal

Casing: above ground In pit In old dug well

Casing sealed? Yes No

Yes, describe: _____

Site protected from obvious hazards, ie. poor drainage,

hazarding animals, buried fuel tanks, etc. Yes No

no, what can be done? _____

Well location cannot be described from a road address,

please sketch approximate location on reverse side of file

copy of well record or attach separate sheet.

Well Log		Metres <input type="checkbox"/>	Feet <input checked="" type="checkbox"/>
From	To	Description	
0	35	gravel	
35	200'	bedrock	

* If drilling is in rock, note depth of fractures which make water.

Well Construction

Surface Casing: Diameter 8"

Length _____ Stick up _____

removed Left in place

Well Casing: Diameter 6"

Length 37' Stick up 2'

Wall thickness: -219

Casing shoe yes no

Completion: well screen slotted pipe

bedrock lined w/pvc 20ft to 200ft open end other

Well screen: stainless galvanized steel

plastic

from _____ to _____ slot width _____

from _____ to _____ slot width _____

Design based on: sieve analysis

estimated slot size

Other screen data: _____

Development method: surge bail air

water jet pump other _____

Static water level below ground: 20'

flowing Rate: _____