

Well Owner: [Redacted]
Address: _____
Phone: [Redacted] Fax: _____

Contractor: _____
Address: _____
Phone: _____ Fax: _____

General Information

Well Location: At owners address Other
Lot # Mile 10, Klondike Highway

Water Quality: Good Poor, why _____

Water Analysis: chemical Biological none

Comments: _____
Taste: _____

Water use: domestic Stock Garden
 Irrigation Heat pump Industry
 Community supply; number of connections _____
 Other _____

Aquifer: Rock Sand and gravel

Well Capacity
Capacity: dry hole Inadequate
 Satisfactory for proposed use

Capacity test: Bail test Air lift Pump test

Length of test 24 hours minutes Rate: 9.59 gpm

Water level at start: 34 ft.

Drawdown at end: 81 ft.

Estimated well capacity: 12 gpm

Was a water sample taken at end of test? Yes No

Final well completion

Cover on casing Welded plate Pitless adaptor
 Aluminium cover Well seal

Casing: above ground In pit In old dug well

Is casing sealed? Yes No

If Yes, describe: _____

Is site protected from obvious hazards, ie. poor drainage, grazing animals, buried fuel tanks, etc. Yes No

If no, what can be done? _____

If well location cannot be described from a road address, please sketch approximate location on reverse side of file copy of well record or attach separate sheet.

Well Log		Metres <input type="checkbox"/>	Feet <input checked="" type="checkbox"/>
From	To	Description	
0	84	sand	
84	207	clay	
207	211	gravel w/water	

* If drilling is in rock, note depth of fractures which make water.

Well Construction

Surface Casing: Diameter _____
Length _____ Stick up _____
 removed Left in place

Well Casing: Diameter 6"
Length 209'6" Stick up 18"
Wall thickness: .250

Casing shoe yes no

Completion: well screen slotted pipe
 open end other

Well screen: stainless galvanized steel
 plastic
from 211' to 208' slot width 40
from _____ to _____ slot width _____

Design based on: sieve analysis
 estimated slot size

Other screen data: _____

Development method: surge bail air
 water jet pump other _____

Static water level below ground: 32 ft

flowing Rate: _____