

Well Owner: [REDACTED]  
 Address: Lot 1366 Km 203, Klondike Hwy  
 Phone: [REDACTED] Fax: \_\_\_\_\_

**General Information**

Well Location:  At owners address  Other

Water Quality:  Good  Poor, why \_\_\_\_\_

Water Analysis:  chemical  Biological  none

Comments: \_\_\_\_\_

Taste: \_\_\_\_\_

Water use:  domestic  Stock  Garden

Irrigation  Heat pump  Industry

Community supply; number of connections \_\_\_\_\_

Other \_\_\_\_\_

Aquifer:  Rock  Sand and gravel

Well Capacity

Capacity:  dry hole  Inadequate

Satisfactory for proposed use

Capacity test:  Bail test  Air lift  Pump test

Length of test 30 hrs minutes Rate: 8 gpm.

Water level at start: 25 ft

Drawdown at end: 29 ft

Estimated well capacity: 20 gpm +

Was a water sample taken at end of test?  Yes  No

**Final well completion**

Cover on casing  Welded plate  Pitless adaptor

Aluminium cover  Well seal

Casing:  above ground  In pit  In old dug well

Is casing sealed?  Yes  No

If Yes, describe: \_\_\_\_\_

Is site protected from obvious hazards, ie. poor drainage, grazing animals, buried fuel tanks, etc.  Yes  No

If no, what can be done? \_\_\_\_\_

If well location cannot be described from a road address, please sketch approximate location on reverse side of file copy of well record or attach separate sheet.

204140230

Contractor: Cathway Water Resources

Address: \_\_\_\_\_

Phone: [REDACTED] Fax: \_\_\_\_\_

Driller: [REDACTED]

| Well Log |     | Metres <input type="checkbox"/> | Feet <input type="checkbox"/> |
|----------|-----|---------------------------------|-------------------------------|
| From     | To  | Description                     |                               |
| 0        | 225 | clay                            |                               |
| 225      | 233 | silty sand                      |                               |
| 233      | 248 | till                            |                               |
| 248      | 255 | gravel. w/water                 |                               |
|          |     |                                 |                               |
|          |     |                                 |                               |
|          |     |                                 |                               |
|          |     |                                 |                               |
|          |     |                                 |                               |
|          |     |                                 |                               |
|          |     |                                 |                               |
|          |     |                                 |                               |

\* If drilling is in rock, note depth of fractures which make water.

**Well Construction**

Surface Casing: Diameter 8"  
 Length 15' Stick up \_\_\_\_\_

removed  Left in place

Well Casing: Diameter 6"

Length 251' Stick up 2 ft

Wall thickness: .250

Casing shoe  yes  no

Completion:  well screen  slotted pipe

open end  other

Well screen:  stainless  galvanized steel

plastic

from 248 to 253 slot width .018

from \_\_\_\_\_ to \_\_\_\_\_ slot width \_\_\_\_\_

Design based on:  sieve analysis

estimated slot size

Other screen data: \_\_\_\_\_

Development method:  surge  bail  air

water jet  pump  other \_\_\_\_\_

Static water level below ground: 25 ft

flowing Rate: \_\_\_\_\_