

Well Owner: [REDACTED]
 Address: Lot 1366 Km 203
Klondike Hwy
 Phone: _____ Fax: _____

Contractor: Cathway 204140278
 Address: _____
 Phone: _____ Fax: _____

General Information

Well Location: At owners address Other

Water Quality: Good Poor, why _____

Water Analysis: chemical Biological none

Comments: _____
 Taste: _____

Water use: domestic Stock Garden

Irrigation Heat pump Industry

Community supply; number of connections _____

Other _____

Aquifer: Rock Sand and gravel

Well Capacity

Capacity: dry hole Inadequate
 Satisfactory for proposed use

Capacity test: Bail test Air lift Pump test

Length of test _____ minutes Rate: _____

Water level at start: _____

Drawdown at end: _____

Estimated well capacity: 20 gpm

Was a water sample taken at end of test? Yes No

Final well completion

Cover on casing Welded plate Pitless adaptor
 Aluminium cover Well seal

Casing: above ground In pit In old dug well

Is casing sealed? Yes No

If Yes, describe: _____

Is site protected from obvious hazards, ie. poor drainage, grazing animals, buried fuel tanks, etc. Yes No

If no, what can be done? _____

If well location cannot be described from a road address, please sketch approximate location on reverse side of file copy of well record or attach separate sheet.

Well Log		Metres <input type="checkbox"/>	Feet <input type="checkbox"/>
From	To	Description	
0	105	Clay	
105	120	Silt	
120	195	thick clay	
195	255	clay then small gravel	
255		water zone	
260	265	gravel	
265	270	water and gravel	
		good well	

* If drilling is in rock, note depth of fractures which make water.

Well Construction

Surface Casing: Diameter _____
 Length _____ Stick up _____

removed Left in place

Well Casing: Diameter 6"

Length 15' Stick up 2'

Wall thickness: 250

Casing shoe yes no

Completion: well screen slotted pipe

open end other

Well screen: stainless galvanized steel

plastic

from 265 to 270 slot width 20

from _____ to _____ slot width _____

Design based on: sieve analysis

estimated slot size

Other screen data: _____

Development method: surge bail air

water jet pump other _____

Static water level below ground: 10'

flowing Rate: 20 gpm