


WELL AND PUMP DATA

Location of Well Hotsprings RA

County	Township Number	Range Number	Section No.	Fraction
	N or S	E or W		1/4 1/4 1/4

Property owner's name and address
 [Redacted] 204140289
Whitehorse, VT

Street Address and City or Distance and Direction from Road Intersections



Well depth 70' Datum point from which all measurements are taken ground

Method of Drilling
 Cable tool Hollow rod Driven Dug
 Direct rotary Air rotary Bucket auger
 Reverse rotary Jetted Flight auger

Use
 Domestic Public supply Industrial
 Irrigation Municipal Commercial
 Test Well Heating or cooling Monitoring

Remarks, Elevation, Source of Data, etc.

Casing Type
 Steel Threaded Welded Height above/below surface
 Galv. Air rotary Drive shoe? Yes No
 PVC Solvent welded Hole diameter:
 SS 5 in to 16 ft Wgt 4 1/2 lb/ft Sch. No. 40
4 1/2 in to 70 ft Wgt lb/ft Sch. No.
 in to ft Wgt lb/ft Sch. No.

Formation Log	Color	Hardness	From	To
<u>Silt + broken Rock</u>			<u>0</u>	<u>8</u>
<u>Red rock</u>	<u>Red</u>		<u>8</u>	<u>70</u>
<u>12 gpm at 42</u>				
<u>previous water at 30' dried up</u>				

Intake Portion of Well
 Screen type None or open hole from ft to
 Manufacturer Dia
 Material Length
 Fittings
 Set between ft and ft Slot
 ft and ft Slot
 ft and ft Slot

Filter Pack
 Source Gradation
 Method of installation Composition
 Volume used Depth to top of f p

Grout
 Used? Yes No Volume used
 Neat Cement Bentonite
 Method of installation
 Depth from ft to
 from ft to

Development
 Method Air Duration 1 hr
 Dates Sand content after hrs
 Chemicals used

Static Water Level
22 ft below above grade
 Date measured

Pumping Water Level
 ft below above grade Date
 After hrs pumping at

Specific Capacity 12.5 gpm/ft of drawdown at hour
 Date

Pump
 Date installed Type
 Manufacturer Model No
 H.P. Volts Capacity
 Depth of pump intake setting No. of stages
 Oil Water lubrication Power source
 Material of drop pipe bowls
 shafting impellers Bowl dia
 Column pipe dia Length Modifications

Well Head Completion
 Pileless adaptor Basement offset Distance above grade

Nearest Sources of Possible Contamination
 ft Direction Type
 Well disinfected upon completion? Yes No

Geophysical Logs Run

Contractor Name and Address
White Water Resources
Box 33012 Whitehorse VT 05455

Name of Driller

Water Quality
 Sample taken? Yes No
 Where analyzed
Aug 27/96