



Field Report

802030017

13 MacDONALD ROAD
WHITEHORSE, YUKON
Y1A 4L1

PHONE (403) 633-3070
TELEX 036-8496

Started June 27 1992

Completed June 27 1992

NAME AND ADDRESS OF CLIENT	DESCRIPTION OF WORK	LOCATION OF WORK
Murphy Construction	W / W	Fire Hall at Rock Creek
	92-1A-20	

FORMATION LOG			DESCRIPTION OF WORK	TIME			
FROM	TO	FORMATION		DATE	FROM	TO	HOURS
			MOVE				
			move on set up	June 27	11:30	12:30	1
0	37	Gr	sand cobs silt	"	12:30	2:00	1.5
37	40	Gr.	sand some silt				
40	41	BR					
			set screen	"	2:00	2:30	0.5
			Develop	"	2:30	4:30	2
			move off to Dawson	"	4:30	6:00	1.5

Rcrd. of Casing & Pipe				Remarks:
Size	Type	Size	Type	
6 5/8				20 GPM
Feet	Inch	Feet	Inch	1-odex shoe
38'				18-slot screen
				K Packer
				4 3/8" bit Pin

Static Level		Total Rig Time	hrs.
Ground Level	4'	Total Standby	hrs.
Top Of Casing		Drilling Mud	sacks

SIGNATURES

MIDNIGHT SUN.....
TITLE.....

CLIENT.
TITLE.. ..



Midnight Sun Drilling Co. Ltd.
13 MacDonald Rd.
Whitehorse, Yukon Y1A 4L1
Phone: (403) 633-3070
Fax: (403) 633-5758

FAX TRANSMITTAL

TO: [REDACTED] DATE: Nov 4/92 TIME: _____

COMPANY: MURPHY CONST. ADDRESS: _____

FROM: [REDACTED] FAX #: 993-5076

of pages including cover: _____

NOTE: if the transmission is incomplete or if you have any questions please contact the writer via Fax or Phone.

MESSAGE: _____

EO: ENCLOSURE

① SKETCH OF WELL

② DRAIN LOG OF HOLE

③ PUMP MODEL



④ ENVIRONMENTAL HEALTH REPORT

⑤ CHEMICAL ANALYSIS OF WATER

⑥ WELL YIELD TEST

⑦ RECOVERY TEST

⑧ GRAPH OF ⑥ AND ⑦






Midnight Sun Drilling Co. Ltd.

DATE Nov 3/92

PAGE NO _____

PROJECT Water Well Rock Canyon Fire Hall





Midnight Sun Drilling Co. Ltd.

DATE Nov 3/92

PAGE NO. _____

PROJECT MURPHY CONSTRUCTION ROCK CREEK FIREHALL

Pump

- $\frac{1}{2}$ H.P. 230 VOLT SKI0B5E-5P MONARCH
Pump Suction Set At 34'

