

Well ID:

To be assigned by Dept. Of Environment

INSTRUCTIONS FOR COMPLETING THE FORM

- Additional information is provided at the bottom of this form on page 2.
- Question can be directed to Water Resources at 867 667-3171.
- All well construction measurements shall be reported to 0.1 m or 0.3 ft.

- Please print clearly in blue or black ink.
- Completion and submission of this form is the responsibility of the drilling contractor.
- Please specify metric or imperial units for all measurements.

WELL LOCATION AND OWNER'S INFORMATION

A1 Well Name:

Optional (i.e. City Well No. 2)

A2 Drilled For:

A3 Street Address of Well Location: Km 150.1 South Klondike
 Lot 1056, Plan 89-104, Quad 105D/10

A4 Town / Village / Area / Lot #: White horse

A5 UTM Coordinates (using handheld GPS): NAD 8 3 Zone


Easting Northing

A6 Elevation of Top of Casing: m / ft ASL

A7 Accuracy of GPS: +/- m / ft

A8 Purpose of Wells

- | | | | |
|----------------------------------------------|---------------------------------------|----------------------------------------------------|--------------------------------------------------------------------------------------------------|
| <input checked="" type="checkbox"/> Domestic | <input type="checkbox"/> Test Well | <input type="checkbox"/> Irrigation | <input type="checkbox"/> Environmental (Quality) |
| <input type="checkbox"/> Commercial | <input type="checkbox"/> Municipal | <input type="checkbox"/> Observation - Water Level | <input type="checkbox"/> Other (please identify use) |
| <input type="checkbox"/> Industrial | <input type="checkbox"/> Agricultural | <input type="checkbox"/> Public/Recreational | |



LOG OF OVERBURDEN AND BEDROCK MATERIALS (All depths are below ground surface, circle appropriate units, use descriptors provided)

EXAMPLE ONLY		(brown, grey, green, black, redish, beige, olive, yellowish)	CLAY, SILT, SAND, GRAVEL, COBBLES, BOULDERS, BEDROCK	"trace" <10% (i.e. SILT trace gravel) "some" 10-20% (i.e. SAND some gravel) "silty / sandy / gravelly" 20-30% (i.e. silty SAND) "and sand" or "and gravel" 35-50%	MOISTURE: dry / moist / saturated (wet) HARDNESS: soft / hard / very hard
B2 From		B4 General Colour	B5 Most Common Material	B6 Secondary Materials	B7 General Description
0	35	grey	gravel		dry
75	100	grey	Sand	Silt	dry
100	145	grey	gravel	boulders	dry
145	154	grey	gravel	Clay	moist
155	160	grey	gravel		wet

B8 Permafrost Encountered: NO YES If yes, indicated depth (m / ft): from: to:

WELL CONSTRUCTION (Continues on Page 2)

Date Well Completed 20070711
 Y Y Y Y M M D D

C1 Drilling Method Air Rotary (Conventional) Dug Other (please specify)

Reverse Air Rotary Cable Tool

Mud Rotary Auger (Hollow / Solid Stem)

C2 Well Type: In what geological material is the water producing zone located?
 OVERBURDEN BEDROCK

C3 Outside Diameter 6.75 (cm / in)

C4 Casing Material Steel Plastic Other

C5 Casing Wall Thickness 2.19 (cm / in)

C6 Casing Depth to: 156 (m / ft)

C7 Other Comments Regarding Casing: Installed with Strater Shoe

Surface / Environmental Seal (depth below ground surface, please circle appropriate units)

C8 Seal Material Type: Bentonite (i.e. Bentonite)
C9 Diameter of Seal: 10' x 15" (cm / in)
C10 Seal Depth from: (m / ft)
C11 Seal Depth to: (m / ft)
C12 Volume Placed: (m³ / ft³)

Gravel Pack (depth below ground surface, please circle appropriate units)

C13 Gravel Pack: NO
If yes, indicated depth (m / ft):
from: to: Indicate diameter of material: (mm / inches) Material type: (i.e. silica)

Well Screen Information (depth below ground surface, please circle appropriate units)

C14 Outside Diameter: 5 (cm / in)
C15 Screen Material: Stainless Steel
C16 Screen Type: Continuous Wire Wrap
C17 Depth from: 156 (m / ft)
C18 Depth to: 160 (m / ft)
Slot Size / Perforation Dia: 30 Thou. / mm / inches

WELL DEVELOPMENT AND STATUS

D1 Well Developed by: Air Jetting / Air Lifting
D2 Well Head Completion: Pitless Adaptor
D3 Well Head Stick-up: 16" (above ground surface)
D4 Static Water Level: 103 (below top of casing)
D5 Well Yield Estimate: 12 (Lps / gpm)
D7 Well Abandonment Status: NO
D8 Method Used to Estimate Well Yield: Air Lifting

PUMPING TEST RECORD AND GROUNDWATER QUALITY

(All depths below ground, circle appropriate units)

E1 Pumping Test Information

Pumping Test Start Date:
Static Water Level (SWL): (m / ft)
Pump Intake Set at: (m / ft)
Duration of pumping: hrs min
Final Water Level (FWL) at end of Pumping Test: (m / ft)

RECOMMENDATIONS

Recomm. Pump Depth: (m / ft)
Recomm. Pumping Rate: (Lps / gpm)
If flowing, provide rate: (Lps / gpm)

F1 Well Water Level Drawdown/Recovery DATA

Table with 4 columns: Time (min), Water Level (m / ft), Time (min), Water Level (m / ft). Rows for 0 (SWL), 0 (FWL) and times 1, 2, 3, 4, 5, 10, 15, 20, 25, 30, 40, 50, 60.

G1 GROUNDWATER QUALITY

Field Data
Date Measurements Taken:
Electrical Conductivity: uS
pH:
Temperature: °C

Turbidity/Sand Content

Clear
Slightly turbid/cloudy
Moderately turbid/cloudy
Turbid/cloudy
Trace sand present
No sand present

Groundwater Type

Salty
Sulphur / Egg Odour
Organic Taste / Odour
Metallic Taste
Other:

Well Disinfection

Was the well disinfected upon completion of the pump installation? YES NO

Briefly describe method of well disinfection.

Bleach

Bacteria Testing

Was a sample taken? YES NO
Date Sample Taken:
If yes, indicate the name of the laboratory.

Chemical Analysis of Water

Was a sample taken? YES NO
Date Sample Taken:
If yes, indicate the name of the laboratory.

WELL CONTRACTOR

H1 Name of Contractor / Drilling Company:
H2 Name of Driller(s):
H3 Address of Driller:
Date Submitted to Dept. Of Environment

CONSULTANT (If applicable)

I 1 Company Name:
I 2 Company Address:
I 3 Report Reference:
I 4 Report Date:

ADDITIONAL INSTRUCTIONS

Upon completing this form, please mail or fax it to:
Water Resources Section (V-310), Department of Environment, Government of Yukon Box 2703, Whitehorse, Yukon, Canada Y1A 2C6
Please feel free to contact us at:
Phone: (867) 667-3171, Toll free (in Yukon): (1-800) 661-0408, local 3171
Fax: (867) 667-3195 E-mail: Water.Resources@gov.yk.ca

Personal information contained on this form is collected under the authority of the Access to Information and Protection of Privacy (ATIPPA) Act, Section 29 (c) and will be used to compile a public database of well and ground water information. For further information contact the Manager of Hydrology, Water Resources at (867) 667-3223, toll free within Yukon 1-800-661-0408 Ext 3223.

I have read the above clause and understand the purpose for collection of personal information.

Signature of Well Owner