



Government
Department of Environment
Water Resources Section V-310
Yukon Water Well Registry
Box 2703 Whitehorse, Yukon Y1A 2C6

Well ID: 1107 110+
To be assigned by Dept. Of Environment

Well Record Page 1 of 2
**WATER WELL
DRILLERS FORM**
Metric Imperial

INSTRUCTIONS FOR COMPLETING THE FORM

1. Additional information is provided at the bottom of this form on page 2.
2. Question can be directed to Water Resources at 867 667-3171.
3. All well construction measurements shall be reported to 0.1 m or 0.3 ft.
4. Please print clearly in blue or black ink.
5. Completion and submission of this form is the responsibility of the drilling contractor.
6. Please specify metric or imperial units for all measurements.

WELL LOCATION AND OWNER'S INFORMATION

A1 Well Name: Optional (i.e. City Well No. 2)

A2 Drilled For: [REDACTED] First Name Last Name Company / Department / Organization

A3 Street Address of Well Location: 1312-2 Echo Valley road

A4 Town / Village / Area / Lot #: Yukon Lot 1318-2

A5 UTM Coordinates (using handheld GPS): NAD 8 3 Zone 08

Easting: 485038 Northing: 6741925

A6 Elevation of Top of Casing: 2438 m @ASL

A7 Accuracy of GPS: 18 +/- m @

Sketch of Well Location
In sketch, indicate distances from property line, septic field, fuel tank(s) and building. Please include North arrow.

A8 Purpose of Wells

- Domestic
- Commercial
- Industrial
- Test Well
- Municipal
- Agricultural
- Irrigation
- Observation - Water Level
- Public/Recreational
- Environmental (Quality)
- Other (please identify use)

LOG OF OVERBURDEN AND BEDROCK MATERIALS (All depths are below ground surface, circle appropriate units, use descriptors provided)

EXAMPLE ONLY →	CLAY, SILT, SAND, GRAVEL, COBBLES, BOULDERS, BEDROCK		MOISTURE: dry / moist / saturated (wet)
	brown	SAND	soft and saturated
Depth (m) (ft)	B4 General Colour	B5 Most Common Material	B6 Secondary Materials
B2 From B3 To			B7 General Description
0 30	grey	clay	rock
30 48	grey	gravel	rock sand
48 88	black	bedrock	

B8 Permafrost Encountered: NO YES If yes, indicated depth (m) (ft): from to

WELL CONSTRUCTION (Continues on Page 2)

Date Well Completed 2019 08 28 Example: 2005 01 31
Y Y Y Y M M D D

- C1 Drilling Method Air Rotary (Conventional) Dug Other (please specify) C2 Well Type: In what geological material is the water producing zone located? OVERBURDEN BEDROCK
- Reverse Air Rotary Cable Tool Auger (Hollow / Solid Stem)

Casing (depth below ground surface, please circle appropriate units)

C3 Outside Diameter 6.825 (cm) (in) C4 Casing Material Steel Plastic Other C5 Casing Wall Thickness .3125 (cm) (in) C6 Casing Depth to: 43 (m) (ft) C7 Other Comments Regarding Casing:

Surface / Environmental Seal (depth below ground surface, please circle appropriate units)

C8 Seal Material Type: foam bentonite (i.e. Bentonite)
C9 Diameter of Seal: 10 (cm)
C10 Seal Depth from: 0 (m)
C11 Seal Depth to: 10 (m)
C12 Volume Placed: (m³)

Gravel Pack (depth below ground surface, please circle appropriate units)

C13 Gravel Pack: NO
If yes, indicated depth (m): from: to: Indicate diameter of material: (mm/inches) Material type: (i.e. silica)

Well Screen Information (depth below ground surface, please circle appropriate units)

C14 Outside Diameter: 5 (cm)
C15 Screen Material: Stainless Steel
C16 Screen Type: Continuous Wire Wrap
C17 Depth from: 43 (m)
C18 Depth to: 48 (m)
Slot Size / Perforation Dia: 0.20 (Thou./mm/inches)

WELL DEVELOPMENT AND STATUS

D1 Well Developed by: Surge Block, Water Jetting, Air Jetting / Air Lifting, Bailing, Pumping
D2 Well Head Completion: Well House, Pitless Adaptor, Well Pit (NOT PERMITTED), None
D3 Well Head Stick-up: 2 (m)
D4 Static Water Level: 14 (m)
D5 Well Yield Estimate: 18 (Lps)
D6 Final Well Status: Water Supply (in use), Stand by (Back-up), Observation
D7 Well Abandonment Status: Was the well properly decommissioned with bentonite grout? YES
D8 Method Used to Estimate Well Yield: Air Lifting, Bailing, Pumping Test

PUMPING TEST RECORD AND GROUNDWATER QUALITY

(All depths below ground, circle appropriate units)

E1 Pumping Test Information
Pumping Test Start Date: Y Y Y Y M M D D

Static Water Level (SWL): (m/ft)

Pump Intake Set at: (m/ft)

Duration of pumping: hrs min

Final Water Level (FWL) at end of Pumping Test: (m/ft)

G1 GROUNDWATER QUALITY

Field Data
Date Measurements Taken: Y Y Y Y M M D D

Electrical Conductivity: uS
pH:
Temperature: °C

Groundwater Type
Salty
Sulphur / Egg Odour
Organic Taste / Odour
Metallic Taste
Other:

RECOMMENDATIONS

Recomm. Pump Depth: (m)
Recomm. Pumping Rate: (Lps / gpm)
If flowing, provide rate: (Lps / gpm)

Turbidity/Sand Content
Clear
Slightly turbid/cloudy
Moderately turbid/cloudy
Turbid/cloudy
Trace sand present
No sand present

Well Disinfection
Was the well disinfected upon completion of the pump installation? YES NO
Briefly describe method of well disinfection.

F1 Well Water Level Drawdown/Recovery DATA

Table with 4 columns: Time (min), Water Level (m/ft) for Drawdown, Time (min), Water Level (m/ft) for Recovery. Rows include 0 (SWL), 0 (FWL), 1, 2, 3, 4, 5, 10, 15, 20, 25, 30, 40, 50, 60.

Bacteria Testing
Was a sample taken? YES NO
Date Sample Taken: Y Y Y Y M M D D

Chemical Analysis of Water
Was a sample taken? YES NO
Date Sample Taken: Y Y Y Y M M D D

Signature of Primary Driller: [Redacted]
Y Y Y Y M M D D

CONSULTANT (if applicable)
1 Company Name:
2 Company Address:
3 Report Reference:
4 Report Date: Y Y Y Y M M D D

ADDITIONAL INSTRUCTIONS

Upon completing this form, please mail or fax it to: Water Resources Section (V-310), Department of Environment, Government of Yukon Box 2703, Whitehorse, Yukon, Canada Y1A 2C6

Personal information contained on this form is collected under the authority of the Access to Information and Protection of Privacy (ATIP) Act, Section 29 (c) and will be used to compile a public database of well and ground water information.