

NOT ENTERED
no spatial info

Well Owner: [REDACTED]
Address: East ST Lot 25
New Caledonia Territory
Phone: _____ Fax: _____

Factor: Cathway
Address: Box 21048 Whitehorse
Phone: 668-7208 Fax: _____

General Information

Well Location: At owners address Other

Water Quality: Good Poor, why _____

Water Analysis: chemical Biological none

Comments: _____

Taste: _____

Water use: domestic Stock Garden

Irrigation Heat pump Industry

Community supply; number of connections _____

Other _____

Aquifer: Rock Sand and gravel

Well Capacity

Capacity: dry hole Inadequate

Satisfactory for proposed use

Capacity test: Bail test Air lift Pump test

Length of test _____ minutes Rate: _____

Water level at start: _____

Drawdown at end: _____

Estimated well capacity: 4 gpm

Was a water sample taken at end of test? Yes No

Final well completion

Cover on casing: Welded plate Pitless adaptor

Aluminium cover Well seal

Casing: above ground In pit In old dug well

Is casing sealed? Yes No

If Yes, describe: _____

Is site protected from obvious hazards, ie. poor drainage, grazing animals, buried fuel tanks, etc. Yes No

If no, what can be done? _____

If well location cannot be described from a road address, please sketch approximate location on reverse side of file copy of well record or attach separate sheet.

Well Log		Metres <input type="checkbox"/>	Feet <input type="checkbox"/>
From	To	Description	
0	90	Gravel & Sand	
90	180	Gravel & clay mix	
180	250	Gravel & clay mix	
250	255	bedrock water	

zone: 8
UTM N: 6703962
UTM E: ~~540~~ 540359

* _____ inch
Make water.

Well Construction

Surface Casing: Diameter _____
Length _____ Stick up _____

removed Left in place

Well Casing: Diameter 6"

Length 15' Stick up 2'

Wall thickness: 250

Casing shoe yes no

Completion: well screen slotted pipe
 open end other

Well screen: stainless galvanized steel
 plastic

from _____ to _____ slot width _____
from _____ to _____ slot width _____

Design based on: sieve analysis
 estimated slot size

Other screen data: _____

Development method: surge bail air

water jet pump other _____

Static water level below ground: 60'

flowing Rate: 4 gal