

NOT ENTERED
no spatial info

Well Owner: [REDACTED]
Address: Vista RD Lot 1472
Phone: _____ Fax: _____

Contractor: Cathway
Address: Box 21048 Whitehorse YT
Phone: 668-7208 Fax: _____

General Information

Well Location: At owners address Other
Water Quality: Good Poor, why _____
Water Analysis: chemical Biological none
Comments: _____
Taste: _____
Water use: domestic Stock Garden
 Irrigation Heat pump Industry
 Community supply; number of connections _____
 Other _____

Aquifer: Rock Sand and gravel
Well Capacity
Capacity: dry hole Inadequate
 Satisfactory for proposed use

Capacity test: Bail test Air lift Pump test
Length of test _____ minutes Rate: _____
Water level at start: _____
Drawdown at end: _____
Estimated well capacity: 5 gpm

Was a water sample taken at end of test? Yes No
Final well completion
Cover on casing Welded plate Pitless adaptor
 Aluminium cover Well seal

Casing: above ground In pit In old dug well
Is casing sealed? Yes No
If Yes, describe: _____
Is site protected from obvious hazards, ie. poor drainage, grazing animals, buried fuel tanks, etc. Yes No
If no, what can be done? _____

If well location cannot be described from a road address, please sketch approximate location on reverse side of file copy of well record or attach separate sheet.

Well Log		Metres <input type="checkbox"/>	Feet <input checked="" type="checkbox"/>
From	To	Description	
0	10'	clay sand mix there at	
10	300	bedrock 5 gal min	
		good well	
zone: 8 UTM N: 6751167 UTM E: 484188			

* If _____
make water.

Well Construction
Surface Casing: Diameter _____
Length _____ Stick up _____
 removed Left in place

Well Casing: Diameter 6"
Length 15' Stick up 2'
Wall thickness: 250
Casing shoe yes no

Completion: well screen slotted pipe
 open end other

Well screen: stainless galvanized steel
 plastic
from _____ to _____ slot width
from _____ to _____ slot width

Design based on: sieve analysis
 estimated slot size

Other screen data: _____
Development method: surge bail air

water jet pump other _____
Static water level below ground: 80'
 flowing Rate: 5 gpm