

NOT ENTERED
no spatial info

Well Owner:
Address: March Lake Lot 60
New Constabulary
Phone: _____ Fax: _____

Contractor: Cathway
Address: _____
Phone: _____ Fax: _____

General Information

Well Location: At owners address Other

Water Quality: Good Poor, why _____

Water Analysis: chemical Biological none

Comments: _____
Taste: _____

Water use: domestic Stock Garden
 Irrigation Heat pump Industry
 Community supply; number of connections _____
 Other _____

Aquifer: Rock Sand and gravel

Well Capacity
Capacity: dry hole Inadequate
 Satisfactory for proposed use

Capacity test: Bail test Air lift Pump test

Length of test _____ minutes Rate: _____

Water level at start: _____

Drawdown at end: _____

Estimated well capacity: 12 gpm

Was a water sample taken at end of test? Yes No

Final well completion

Cover on casing Welded plate Pitless adaptor
 Aluminium cover Well seal

Casing: above ground In pit In old dug well

Is casing sealed? Yes No

If Yes, describe: _____

Is site protected from obvious hazards, ie. poor drainage, grazing animals, buried fuel tanks, etc. Yes No

If no, what can be done? _____

If well location cannot be described from a road address, please sketch approximate location on reverse side of file copy of well record or attach separate sheet.

Well Log		Metres <input type="checkbox"/>	Feet <input checked="" type="checkbox"/>
From	To	Description	
0	30	Clay	
30	60	Sand and some rock	
60	105	clay & gravel mix	
105	150	clay & gravel mix	
150	180	clay Heavy	
180	185	Water 6.40 ft	
		gravel Zoned	

zone: 8
UTM N: 67 03561
UTM E: 540505

* If _____

Well Construction
Surface Casing: Diameter _____

Length _____ Stick up _____
 removed Left in place

Well Casing: Diameter 6"
Length 15' Stick up 2'

Wall thickness: 2.50
Casing shoe yes no

Completion: well screen slotted pipe
 open end other

Well screen: stainless galvanized steel
 plastic

from 181 to 185 slot width 15
from _____ to _____ slot width _____

Design based on: sieve analysis
 estimated slot size

Other screen data: _____

Development method: surge bail air
 water jet pump other _____

Static water level below ground: 10'

flowing Rate: 1.5 gpm