WELL FORM [redacted]

W59

sheet ____ of ____

6" - 12" • Water Wells • Pump Installation • Exploration • Dual Rotary Air Rig • Pilings

Owner name: [redacted]

Mailing address: ____ City / Town: Whitehorse Prov. / Terr. YT Postal Code ____

Well Location Address: Street No. 169 Street name War Eagle Way City / Town Nauch Bridge

OR Legal description: Lot ____ Plan ____ D.L. ____ Block ____ **OR PID:** ____ **AND Description of well location** (attach sketch if nec.): To Right of main House Approx 10 betwe

NAD 83: Zone: ____ **AND UTM Easting:** 0[redacted]492568 E m **OR Latitude:** ____

UTM Northing: 6733800 N m **Longitude:** ____

UTM ZONE 8
4925608 E
6733800 N

Method of drilling: ☐ air rotary ☑ dual rotary ☐ cable tool ☐ mud rotary ☐ auger ☐ driving ☐ jetting ☐ other ( )

Orientation of well: ☑ vertical ☐ horizontal Ground elevation 704 ft (asl) Method: ____

Class of well: ____

Water supply wells, indicate water use: ☑ private domestic ☐ water supply system ☐ irrigation ☐ commercial or in

☐ other (specify) ____

LITHOLOGIC DESCRIPTION

From ft (bgl)	To ft (bgl)	Surficial Material: Clay	Silt	Till	Sand with clay/silt	Sand, fine-med	Sand, med-coarse	Sand with gravel	Bedrock Material: Siltstone/Shale	Sandstone	Granodiorite	Limestone	Basalt	Volcanic	Crystalline	Other Surficial Bedrock	Color: Red	Orange	Brown	Black	Light Grey	Blue	Green	Dark Grey	Hardness: Very Hard	Hard	Dense / Stiff	Loose	Water Content: Dry	Moist	Wet	High Production	Lost circulation	Not available	Observations (e.g. other geological materials (e.g. boulders), est. water bearing flow (USgpm), or closure details)
0	6	●						●																											
6	120																		●					●											B/R
120	280																		●				●	●											different colouring
																																			water
280	294																																		7 GPM

CASING DETAILS

From ft (bgl)	To ft (bgl)	Dia in	Casing Material / Open Hole	Wall Thickness in	Drive Shoe
0	18	6⅝	Steel	.219	D.R

Surface seal: Type Concrete Depth 15' ft

Method of installation ☑ Poured ☐ Pumped Thickness 12" in

Backfill: Type ____ Depth ____ ft

Liner: ☑ PVC ☐ Other (specify): ____

Diameter 4.5 in Thickness .250 in

From 294 ft (bgl) To 14 ft (bgl)

Perforated: From ____ ft (bgl) To ____ ft (bgl)

SCREEN DETAILS

From ft (bgl)	To ft (bgl)	Dia in	Type	Slot Size

Intake: ☐ Screen ☐ Open bottom ☐ Uncased hole

Screen type: ☐ Telescope ☐ Pipe size

Screen material: ☐ Stainless steel ☐ Plastic ☐ Other: ____

Screen opening: ☐ Continuous slot ☐ Slotted ☐ Perforated pipe

Screen bottom: ☐ Bail ☐ Plug ☐ Plate ☐ Other: ____

Filter pack: From ____ ft To: ____ ft Thickness: ____ in

Type and size of material: ____

DEVELOPED BY

☑ Air lifting ☐ Surging ☐ Jetting ☐ Pumping ☐ Bailing

Other (specify): ____ Total duration: ____ hrs

Notes: ____

WELL YIELD ESTIMATED BY

☐ Pumping ☑ Air lifting ☐ Bailing ☐ Other (specify): ____

Rate: ____ USgpm Durtation: ____ hrs

SWL before test: ____ ft (btoc) Pumping water level: ____ ft (btoc)

OBVIOUS WATER QUALITY CHARACTERISTICS

☐ Fresh ☐ Salty ☑ Clear ☐ Cloudy ☐ Sediment ☐ Gas

Colour / Odour: ____ Water sample collected: ☐

WELL DRILLER (print clearly)

Name (first, last): [redacted]

Consultant (if applicable; name & company) ____

Signature of Driller Responsible [redacted]

FINAL WELL COMPLETION DATA

Total depth drilled: 294 ft Finished well depth: 294 ft (bgl)

Final stick up: 18" in Depth to bedrock : ____ ft (bgl)

SWL: 92 ft (bgl) Estimated well yield 25 USgpm

Artesian flow: ____ USgpm, or Artesian pressure: 25 ft

Type of well cap: Locking Well disinfected: ☑ Yes ☐ No

Where well ID plate is attached: ____

WELL CLOSURE INFORMATION

Reason for closure: ____

Method of closure: ☐ Poured ☐ Pumped

Sealant Material: ____ Backfill material: ____

Details of closure: ____

DATE OF WORK (yyyy/mm/dd)

Started: Oct / 18 **Completed** Oct / 18

Comments: ____

PLEASE NOTE: The information recorded in this well report describes the works and hydrogeologic conditions at the time of construction, alteration or closure as the case may be. Well yield, well performance and water quality are not guaranteed as they are influenced by a number of factors, including natural variability, human activities and condition of the works, which may change over time.

WHITE: CUSTOMER COPY | YELLOW: YTG COPY | PINK: DRILLER COPY